

CAPCO

QS SPECIFICATIONS

BETA DRYWALL PARTITION SYSTEMS

BETA 76mm Moisture Resistant Drywall using 12mm Fibre Cement Boards

BETA 76mm Moisture Resistant Drywall comprising 52mm floor track fixed at 600mm centres with 5/6/36 wall anchors and natural anodised aluminium ceiling and wall channel at ceiling fixed with 4,2 x 13mm wafer-tek screws. Friction fit 51mm GMS drywall studs into track and ceiling channel at 600mm centres. Fix 12mm Shera tapered edge fibre cement board to both sides of GMS framing with 32mm fibre cement screws at 230mm centres. Apply 50mm self-adhesive fibreglass mesh tape to tapered edge joints and flush joint with Knauf Satengips Jointing Compound. All screws to be spotted with joint compound. Fit 75mm natural anodised aluminium skirting to both sides of drywall.