

CAPCO

QS SPECIFICATIONS

FLUSH PLASTERED CONCEALED TEE SUSPENDED CEILINGS

CAPCO 6,5mm Plasterboard Square Edge & T38/35G Galvanised Concealed Tee Grid System

Supply and install CAPCO 3,600m T38/35G main tees at 1,200m centres in one direction and CAPCO 1,200m T38/35G cross tees at 300mm centres perpendicular to main tees. Main tees to be suspended at 1,200m centres by means of 25 x 25 x 0,6mm GMS angle hangers fixed to bulb of main tee with 4,2 x 13mm wafer-tek screws and to slab with 6 x 40mm express nails and M6 washers. Fit 6,5mm thick CAPCO standard gypsum square edge board to underside of grid system with 25mm drywall screws at 150mm centres. Cover all drywall screw heads with CAPCO Jointing Compound. Apply 7mm PVC "H" Profile to joints. Installation to be in accordance with CAPCO and SABISA installation instructions.