



FIRELAB

TITLE : Report on the Large-scale Fire Resistance Properties of the **CAPCO FireShield Ceiling System**

REQUESTED BY : **CAPCO (Pty) Ltd**
PO Box 4203
RIVERHORSE VALLEY EAST
Durban
4017

CONTRACT No : FTC 20/003

ISSUE No : 3 (09/10/2020)

DATE : 15 September 2020

Copyright is vested with **FIRELAB cc** Reg no: 2005/087037/23

The use of this report is subject to the condition that it will only be published in full, an abridged version can only be approved by **FIRELAB**

SCOPE

This report classifies the Fire Resistance Properties of the **CAPCO FireShield Ceiling System** when tested and classified in accordance with the **SANS 10177 – 2** test protocol.

Section 1: Detailed information on the specimen construction

Section 2: Test protocol used for classification

Section 3: Observations made, temperatures recorded with photographs taken before, during and after the **SANS 10177 – 2** test

Section 4: Discussion of results

Section 5: Conclusion

Annexure “A”: Company information

Annexures “B”: System information and detailed drawing supplied by **CAPCO**

TABLE OF CONTENTS

LIST OF FIGURES AND TABLES	1
1. SYSTEM DESCRIPTION	2
2. FIRE RESISTANCE: SANS 10177 – PART 2:2005	3
2.1. TEST PROCEDURE	4
2.2. TEST EQUIPMENT	4
3. TEST RESULTS.....	5
4. DISCUSSION OF RESULTS.....	12
5. CONCLUSION	13
ANNEXURE “A”	14
ANNEXURE “B”	15

LIST OF FIGURES AND TABLES

Figure 1.1: The FireShield Ceiling system from the unexposed side prior to the test.....	3
Figure 1.2: The FireShield Ceiling system with thermocouples from the unexposed side.....	3
Table 3.1: Observations recorded during the SANS 10177 – 2 test	5
Figure 3.1: Furnace temperatures recorded during the large-scale FR test.....	6
Figure 3.2: Temperatures recorded on the surface of the specimen.....	7
Figure 3.3: Charring and slight buckling of the perimeter fixing.....	8
Figure 3.4: Smoke release on the perimeter.....	8
Figure 3.5: Bottom board fragmenting (mid-section of specimen).....	9
Figure 3.6: Pin hole formed in the specimen.....	9
Figure 3.7: Discolouration visible (mid-section joint of specimen)	10
Figure 3.8: Unexposed side of specimen after conclusion of the test	10
Figure 3.9: Exposed side of specimen after conclusion of the test.....	11

1. SYSTEM DESCRIPTION

CAPCO installed the CAPCO FireShield Ceiling System into FIRELAB's Horizontal SANS 10177 – 2 test facility.

Description of the ceiling system:

System: CAPCO FireShield Ceiling System
System Abbr. name: FireShield Ceiling
Proposed Application: Fire Rated Ceiling

System make up:

Board: CAPCO Fire Shield Boards (Gypsum Board)
Plaster: N/A
Length (per board): 3.0 m
Width (per board): 1.2 m
Total Thickness 120 mm

Product Composition:

Grid 1: T38/35G Tee Grid System
Layer 1: 15 mm FireShield Board
Layer 2: 15 mm FireShield Board
Grid 2: 25/75G Omega Furring Channel
Layer 3: 15 mm FireShield Board
Layer 4: 15 mm FireShield Board

Joints:

Sealant: Capco Joining Compound & 50 mm Fibre Tape
Cover Strips: 100 x 0.5 mm Galvanised sheet covering all joints on board layer 1 and 3
Type: Tapered
Fasteners: Drywall Screws at 150 mm Centres

Support:

Main T's: T38/35G Main Tees at 1 200 mm Centres
Secondary T's: T38/35G 1 200 mm Cross Tees at 300 mm Centres
Secondary: Furring Channel Grid at 300 mm Centres
Hangers: 25 x 25 x 0.6 Galvanised @ 750 mm Centres
Clips: N/A (Hangers are fixed with screws)

The test specimen is shown from the exposed and unexposed sides in Figures 1.1 and 1.2 prior to commencement of the test.

The Test Report and results only relate to the product(s) and/or specimen(s) submitted for testing as identified in Section 1 and Annexures and do not apply to any similar product(s) or specimen(s) that has not been tested. This Test Report is only valid for 5 years or until there is a change to the product composition, manufacturing process or previously approved supplier(s).



Figure 1.1: The **FireShield Ceiling** system from the unexposed side prior to the test






Figure 1.2: The **FireShield Ceiling** system from the exposed side

2. FIRE RESISTANCE: SANS 10177 – PART 2:2005

2.1. TEST PROCEDURE

The nominal 3 meter wide by 6 meter long system was tested for fire resistance in the large-scale horizontal air-aspirated diesel furnace. The furnace temperature was controlled to follow the **ISO standard time-temperature curve** as stipulated in **SANS 10177 – 2**.





The **Fire Resistance Rating (FRR)** of the system is determined based on the following criteria:

-  **Stability (R):** The system may not collapse or fail structurally during the test.
-  **Integrity (E):** The system is deemed to have failed should flames be observed on the unexposed side or an opening larger than 6 mm wide or 150 mm long is noted.
-  **Insulation (I):** The temperature on the unexposed surface may not exceed 140 °C plus ambient temperature on average or 180 °C plus ambient maximum at any of the measured surface positions.

The **Stability** and **Integrity** criteria are evaluated through observations which are noted in Table 3.1.

Insulation was measured using 5 thermocouples (TC 1 – TC 5) placed in a grid of equal area onto the surface of the specimen. An additional two thermocouples were used to measure the surface joints (TC 6 & TC 7).

2.2. TEST EQUIPMENT

-  Data logging equipment c/w controller
-  Stopwatch
-  Type K thermocouples
-  **SANS 10177 – 2** Horizontal Test Facility

3. TEST RESULTS

The specimen was tested on 07 September 2020. The average ambient temperature during the test was 23.06 °C.

CAPCO – FireShield Ceiling

OBSERVATIONS DURING THE SANS 10177 – 2 TEST

TIME (hh:mm:ss)	DESCRIPTION
00:00:00	– Test Started –
00:07:40	Smoke release on the middle of the right perimeter
00:08:20	Steam release on the front perimeter
00:10:35	Charring on the smoke release areas
00:33:20	Pin-hole forming in the board between TC 4 & 5
00:40:00	Pin-hole forming in the board behind TC 3
01:02:30	First layer of the boards is starting to collapse
01:17:20	Smoke release from the right joint near the middle
01:22:15	Smoke release from the left joint near the middle
01:25:00	Second layer of boards draping
01:31:30	Smoke release increase on the right joint
01:36:30	Smoke release along the lateral joint on the right
01:40:00	Second layer of boards dropping off and draping
01:52:45	Smoke release increase on the lateral joint
01:53:30	Charring and light cracking on the front left corner
01:55:00	Crack forming near the left side
02:03:00	Hot spot near the middle measured to be approximately 185 °C
02:04:30	Large cracks formed in the middle between TC 4 & 5
02:05:00	– Test Concluded –

Note(s): The peripheral cracking was caused by viewports in the furnace walls, which would not be present in an installation in practice. Thus, the peripheral cracking can be disregarded

Table 3.1: Observations recorded during the SANS 10177 – 2 test




Figure 3.1: Furnace temperatures recorded during the large-scale FR test




Figure 3.2: Temperatures recorded on the surface of the specimen

The Test Report and results only relate to the product(s) and/or specimen(s) submitted for testing as identified in Section 1 and Annexures and do not apply to any similar product(s) or specimen(s) that has not been tested. This Test Report is only valid for 5 years or until there is a change to the product composition, manufacturing process or previously approved supplier(s).



Figure 3.3: Charring and slight buckling of the perimeter fixing



Figure 3.4: Smoke release on the perimeter




Figure 3.5: Bottom board fragmenting (mid-section of specimen)




Figure 3.6: Pin hole formed in the specimen

The Test Report and results only relate to the product(s) and/or specimen(s) submitted for testing as identified in Section 1 and Annexures and do not apply to any similar product(s) or specimen(s) that has not been tested. This Test Report is only valid for 5 years or until there is a change to the product composition, manufacturing process or previously approved supplier(s).



Figure 3.7: Discolouration visible (mid-section joint of specimen)



Figure 3.8: Unexposed side of specimen after conclusion of the test



The Test Report and results only relate to the product(s) and/or specimen(s) submitted for testing as identified in Section 1 and Annexures and do not apply to any similar product(s) or specimen(s) that has not been tested. This Test Report is only valid for 5 years or until there is a change to the product composition, manufacturing process or previously approved supplier(s).



Figure 3.9: Exposed side of specimen after conclusion of the test





4. DISCUSSION OF RESULTS

The **Fire Resistance** requirements in terms of **SANS 10177 – 2**, were achieved as follows:

-  **Stability (R):** The specimen did not collapse.
Stability satisfied for 120 minutes
-  **Integrity (E):** No significant straight through gaps or flaming occurred. There were small pin holes and small cracks observed, but was within allowable limits.
Integrity satisfied for 120 minutes
-  **Insulation (I):** TC 6 reached the maximum allowed single temperature after 2 hours 6 minutes and 30 seconds.
Insulation satisfied for 120 minutes

5. CONCLUSION


The **CAPCO FireShield Ceiling System** was tested for a **Fire Resistance Rating (FRR)** in accordance with the **SANS 10177 – 2** test protocol and the exposed side was classified as follows:


 SANS 10177 – 2	»	FR120
 Stability (R)	»	120 minutes
 Integrity (E)	»	120 minutes
 Insulation (I)	»	120 minutes


.....
Compiled by: **J. Vogel**


.....
Approved by: **J.S. Strydom**

This copy has been produced from a .pdf format electronic file that has been provided by **FIRELAB** to the sponsor of the report and may only be reproduced in full. Extracts or abridgements of reports must not be published without permission of **FIRELAB**. The original signed paper version of this report is the sole authentic version. Only original paper versions of this report bear authentic signatures of the responsible **FIRELAB** staff.

- Company Information -		 FIRELAB
Company Name:	CAPCO (PTY) LTD	
Company Trading Name:	CAPCO	
Company Registration Nr.:	2019/574495/07	
Company VAT Nr.:	4600104667	
Core Business Activities:	DISTRIBUTORS OF CEILING & PARTITION MATERIALS	
Postal Address:	PO BOX 4203 RIVERHORSE VALLEY EAST, DURBAN, 4017.	
Physical Address:	2 COBOBRIK PLACE, RIVERHORSE VALLEY BUSINESS ESTATE, DURBAN, 4017.	
Company contact number:	(031) 569 6090	
Direct Contact Details		
Technical (name):	BARRY GOULD	
Cell phone number:	083 272 1871	
Email address:	barry@capco.co.za	
Financial (name):	BRAD Mc LEARY	
Cell phone number:	083 856 6447	
Email address:	brad@capco.co.za	
- Test & Sample Information -		
Test Required:	2 HOUR FIRE-RATED CEILING	
Sample/Product name:	CAPCO FIRESHIELD BOARD	
Intended Use:	CEILINGS - FIRE-RATED	
Sample/Product Description: <small>(Short description of sample or product submitted for testing, and type of material to be tested)</small>	6,000 x 3,000 mm MILD STEEL FRAMED COVERED TEE SYSTEM USING T38/35G GALVANISED STEEL GRID WITH 2 x 15 mm FIRESHIELD BOARDS THEN G.M.S FURRING CHANNELS AND 2 x 15 mm FIRESHIELD BOARDS BELOW.	

- SANS 10177 Part 2 - - Ceiling Specimen Description -		 FIRELAB
Ceiling system description:		
System name:	CAPCO FIRESHIELD	
System type:	COVERED TEE CEILING SYSTEM	
Proposed Usage:	FIRE-RATED CEILING	
System make up:		
Board:	CAPCO FIRESHIELD BOARDS	
Plaster:	CAPCO JOINTING COMPOUND	
Length (per board):	3,000 m	
Width (per board):	1,200 m	
Overall Thickness:	120 mm	
Product composition (includes skin coat & coating):		
Layer 1:	15mm FIRESHIELD BOARD	
Layer 2:	15mm FIRESHIELD BOARD	
Layer 3:	15mm FIRESHIELD BOARD	
Layer 4:	15mm FIRESHIELD BOARD	
GMS COVER STRIPS:	100 x 0.5 mm GMS SHEET TO COVER ALL JOINTS ON 1ST AND 3RD LAYERS.	
Support:		
T's:	TEE 38 x 35 x 0.35 mm GMS TEES m/TEES @ 1,200 m CENTRES CROSS TEES @ 300m CENTRES.	
Hangers:	25 x 25 x 0.6 mm GALVANISED ANGLE HANGERS.	
GYPSUM BOARD FIXINGS:	25mm DRYWALL SCREWS - LAYER 1 45mm DRYWALL SCREWS - LAYER 2	
GYPSUM BOARD FIXINGS:	25mm DRYWALL SCREWS - LAYER 3 45mm DRYWALL SCREWS - LAYER 4	
PERIMETER FASTENERS:	5/6/36 WALL ANCHORS.	
FURRING CHANNELS:	22 x 75 mm FURRING CHANNELS FIXED TO PRIMARY TEES THROUGH LAYERS 1 AND 2.	
JOINTS:	ALL TAPERED EDGES OF BOARDS FIXED WITH 50 mm SELF-ADHESIVE FIBRE TAPE AND FLUSH JOINTED.	

